

INSTALLATION INSTRUCTIONS FOR PLENUM ADAPTER ACCESSORY FOR CASED INDOOR COOLING/HEAT PUMP COILS

This Plenum Adapter Accessory is for use with the 24.5" wide cased indoor cooling and heat pump coils. This allows a 24.5" wide cased coil to be installed on the 28" wide oil furnace.

APPLICATION

<u>ACCESSORY</u>	<u>COIL MODEL</u>
RXBA-AE	RC*A-60**A*24

<u>CASED COIL WIDTH</u>	<u>FURNACE WIDTH</u>
24.5"	28"

PARTS LIST

<u>ITEM NO.</u>	<u>DESCRIPTION</u>	<u>PART NUMBER</u>
1	PLENUM ADAPTER ASSEMBLY	AS-58335-01

INSTALLATION PROCEDURE

1. Install adapter assembly as shown in Figure 1 on the outlet of furnace.
2. Using duct pliers, bend all bottom flanges on indoor coil up and install on adapter assembly as shown.
3. Seal coil to furnace using metal tape.

Consult the Installation and Operating Instructions of the Indoor Coil for proper installation and operating information.




FIGURE 1