

R					LOCATION 																																								
	SANI-CEPTOR® ACID RESISTANT COATED FLOOR & INDIRECT WASTE DRAINS																																												
	A.R. COATED NON-TRAFFIC TOPS 12" (305) ROUND TOP - DEEP RECEPTORS																																												
	Conforms to ASME A112.6.7/CSA B79.7																																												
	WITH DOME BOTTOM STRAINER WITH SEDIMENT BUCKET																																												
<table style="width: 100%; border: none;"> <tr> <td style="border: none;">☐ Fig. 3400C</td> <td style="border: none;">..... CAULK OUTLET</td> <td style="border: none;">☐ Fig. 3401C</td> <td style="border: none;">☐</td> </tr> <tr> <td style="border: none;">☐ Fig. 3400Y</td> <td style="border: none;">..... NO-HUB OUTLET</td> <td style="border: none;">☐ Fig. 3401Y</td> <td style="border: none;">☐</td> </tr> </table>						☐ Fig. 3400C	 CAULK OUTLET	☐ Fig. 3401C	☐	☐ Fig. 3400Y	 NO-HUB OUTLET	☐ Fig. 3401Y	☐																																
☐ Fig. 3400C	 CAULK OUTLET	☐ Fig. 3401C	☐																																										
☐ Fig. 3400Y	 NO-HUB OUTLET	☐ Fig. 3401Y	☐																																										
FEATURES, OPTIONS & ORDERING INFORMATION																																													
REGULARLY FURNISHED: Cast Iron Flanged Receptor with Seepage Holes, Acid Resistant Coated Interior, and Loose Set Acid Resistant Coated Cast Iron Grate. Aluminum Dome Bottom Strainer or Sediment Bucket as Indicated by Figure Number.																																													
<table style="width: 100%;"> <tr> <td style="width: 50%; vertical-align: top;"> VARIATIONS: ☐ Aluminum Flat Bottom Strainer -FBS ☐ Flashing Clamp -C ☐ L Speedi-Set® Service Weight (02(50) & 03(75) Sizes Only) ☐ LXH Speedi-Set® Extra Heavy (02(50) & 03(75) Sizes Only) ☐ Less Flange (Specify Fig. 3405, 3406) ☐ Polished Aluminum Dome Bottom Strainer -PDBS ☐ S.S. Mesh Lined Bucket -BS ☐ Drain Installation Device -DID </td> <td style="width: 50%; vertical-align: top;"> OPTIONAL MATERIALS: ☐ All Duco Cast Iron Receptor and Grate -CI ☐ All Galvanized Receptor and Grate -G NOTE: This grate is not recommended for any type of traffic including pedestrian traffic. NOTE: Dimensions shown in parentheses are in millimeters. </td> </tr> </table>						VARIATIONS: ☐ Aluminum Flat Bottom Strainer -FBS ☐ Flashing Clamp -C ☐ L Speedi-Set® Service Weight (02(50) & 03(75) Sizes Only) ☐ LXH Speedi-Set® Extra Heavy (02(50) & 03(75) Sizes Only) ☐ Less Flange (Specify Fig. 3405, 3406) ☐ Polished Aluminum Dome Bottom Strainer -PDBS ☐ S.S. Mesh Lined Bucket -BS ☐ Drain Installation Device -DID	OPTIONAL MATERIALS: ☐ All Duco Cast Iron Receptor and Grate -CI ☐ All Galvanized Receptor and Grate -G NOTE: This grate is not recommended for any type of traffic including pedestrian traffic. NOTE: Dimensions shown in parentheses are in millimeters.																																						
VARIATIONS: ☐ Aluminum Flat Bottom Strainer -FBS ☐ Flashing Clamp -C ☐ L Speedi-Set® Service Weight (02(50) & 03(75) Sizes Only) ☐ LXH Speedi-Set® Extra Heavy (02(50) & 03(75) Sizes Only) ☐ Less Flange (Specify Fig. 3405, 3406) ☐ Polished Aluminum Dome Bottom Strainer -PDBS ☐ S.S. Mesh Lined Bucket -BS ☐ Drain Installation Device -DID	OPTIONAL MATERIALS: ☐ All Duco Cast Iron Receptor and Grate -CI ☐ All Galvanized Receptor and Grate -G NOTE: This grate is not recommended for any type of traffic including pedestrian traffic. NOTE: Dimensions shown in parentheses are in millimeters.																																												
OPTIONAL TOP GRATES AND COVERS FOR INDIRECT WASTE APPLICATIONS																																													
<table style="width: 100%;"> <thead> <tr> <th style="width: 10%;">SUFFIX NUMBER</th> <th style="width: 90%;">DESCRIPTION</th> </tr> </thead> <tbody> <tr><td>☐ -10</td><td>..... Less A.R.C. Grate</td></tr> <tr><td>☐ -12</td><td>..... With A.R.C. 1/2 Grate</td></tr> <tr><td>☐ -13</td><td>..... With A.R.C. 3/4 Grate</td></tr> <tr><td>☐ -14</td><td>..... With A.R.C. Grate with 2 1/2" (64) DIA Center Hole</td></tr> <tr><td>☐ -15</td><td>..... With Aluminum Recessed Grate</td></tr> <tr><td>☐ -21</td><td>..... With A.R.C. Grate and 4" (100) DIA A.R.C. Funnel</td></tr> <tr><td>☐ -22</td><td>..... With A.R.C. Grate and 6" (150) DIA A.R.C. Funnel</td></tr> <tr><td>☐ -25</td><td>..... With A.R.C. Grate and 8 1/4(210) x 3 1/4(83) x 4 1/2"(115) High Oval A.R.C. Funnel</td></tr> <tr><td>☐ -26</td><td>..... With A.R.C. Grate and 6(150) x 2 1/2(64) x 1"(25) High Oval A.R.C. Funnel</td></tr> <tr><td>☐ -41</td><td>..... With A.R.C. Solid Cover-42 With A.R.C. 1/2 Solid Cover</td></tr> <tr><td>☐ -43</td><td>..... With A.R.C. 3/4 Solid Cover</td></tr> <tr><td>☐ -44</td><td>..... With A.R.C. Solid Cover with 2 1/2" (64) DIA Center Hole</td></tr> </tbody> </table>						SUFFIX NUMBER	DESCRIPTION	☐ -10	 Less A.R.C. Grate	☐ -12	 With A.R.C. 1/2 Grate	☐ -13	 With A.R.C. 3/4 Grate	☐ -14	 With A.R.C. Grate with 2 1/2" (64) DIA Center Hole	☐ -15	 With Aluminum Recessed Grate	☐ -21	 With A.R.C. Grate and 4" (100) DIA A.R.C. Funnel	☐ -22	 With A.R.C. Grate and 6" (150) DIA A.R.C. Funnel	☐ -25	 With A.R.C. Grate and 8 1/4(210) x 3 1/4(83) x 4 1/2"(115) High Oval A.R.C. Funnel	☐ -26	 With A.R.C. Grate and 6(150) x 2 1/2(64) x 1"(25) High Oval A.R.C. Funnel	☐ -41	 With A.R.C. Solid Cover-42 With A.R.C. 1/2 Solid Cover	☐ -43	 With A.R.C. 3/4 Solid Cover	☐ -44	 With A.R.C. Solid Cover with 2 1/2" (64) DIA Center Hole														
SUFFIX NUMBER	DESCRIPTION																																												
☐ -10	 Less A.R.C. Grate																																												
☐ -12	 With A.R.C. 1/2 Grate																																												
☐ -13	 With A.R.C. 3/4 Grate																																												
☐ -14	 With A.R.C. Grate with 2 1/2" (64) DIA Center Hole																																												
☐ -15	 With Aluminum Recessed Grate																																												
☐ -21	 With A.R.C. Grate and 4" (100) DIA A.R.C. Funnel																																												
☐ -22	 With A.R.C. Grate and 6" (150) DIA A.R.C. Funnel																																												
☐ -25	 With A.R.C. Grate and 8 1/4(210) x 3 1/4(83) x 4 1/2"(115) High Oval A.R.C. Funnel																																												
☐ -26	 With A.R.C. Grate and 6(150) x 2 1/2(64) x 1"(25) High Oval A.R.C. Funnel																																												
☐ -41	 With A.R.C. Solid Cover-42 With A.R.C. 1/2 Solid Cover																																												
☐ -43	 With A.R.C. 3/4 Solid Cover																																												
☐ -44	 With A.R.C. Solid Cover with 2 1/2" (64) DIA Center Hole																																												
<table style="width: 100%; border: none;"> <tr> <td style="width: 10%; text-align: center;">REV.</td> <td style="width: 15%; text-align: center;">DATE</td> <td style="width: 30%; text-align: center;">DESCRIPTION</td> <td style="width: 10%; text-align: center;">BY</td> <td style="width: 10%; text-align: center;">CKD. BY</td> <td style="width: 10%; text-align: center;">WEIGHT POUNDS</td> <td style="width: 10%; text-align: center;">VOLUME CUBIC FEET</td> <td style="width: 15%; text-align: center;">FIGURE NUMBER</td> </tr> <tr> <td style="text-align: center;">4-24-24</td> <td style="text-align: center;">4-19-24</td> <td style="text-align: center;">Revised Variations</td> <td style="text-align: center;">HS</td> <td style="text-align: center;">KV</td> <td></td> <td></td> <td style="text-align: center;">3400, 3401</td> </tr> <tr> <td style="text-align: center;">2-21-24</td> <td style="text-align: center;">7-25-23</td> <td style="text-align: center;">Added ASME Note</td> <td style="text-align: center;">HS</td> <td style="text-align: center;">BW</td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td style="text-align: center;">Revised Variations</td> <td style="text-align: center;">HS</td> <td style="text-align: center;">CL</td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td style="text-align: center;">Removed Function</td> <td style="text-align: center;">HS</td> <td style="text-align: center;">CL</td> <td></td> <td></td> <td></td> </tr> </table>						REV.	DATE	DESCRIPTION	BY	CKD. BY	WEIGHT POUNDS	VOLUME CUBIC FEET	FIGURE NUMBER	4-24-24	4-19-24	Revised Variations	HS	KV			3400, 3401	2-21-24	7-25-23	Added ASME Note	HS	BW						Revised Variations	HS	CL						Removed Function	HS	CL			
REV.	DATE	DESCRIPTION	BY	CKD. BY	WEIGHT POUNDS	VOLUME CUBIC FEET	FIGURE NUMBER																																						
4-24-24	4-19-24	Revised Variations	HS	KV			3400, 3401																																						
2-21-24	7-25-23	Added ASME Note	HS	BW																																									
		Revised Variations	HS	CL																																									
		Removed Function	HS	CL																																									



WARNING: Cancer and Reproductive Harm - www.P65Warnings.ca.gov