



PROJECT NAME _____
LOCATION _____
ARCHITECT _____
ENGINEER _____
CONTRACTOR _____
SUBMITTED BY _____ DATE _____

UNIT SUMMARY

Quantity						
Unit Designation						
Model No.						
Total Cooling						
Sensible Cooling						
Air Ent. Evaporator						
Air Lvg. Evaporator						
Heating Input						
Heating Output						
CFM/ESP						
EER/SEER						
Electrical						
Minimum Ampacity						
Min.-Max. Breaker						
Net Unit Weight						
Accessory						
Catalog Form Number						

ACCESSORIES:

NOTES:

Versus™ Line W951T 4-Way Multi-Position Gas Furnaces

Heating Stages: Single Stage 95% A.F.U.E.

Input Rates: 40-115 kBTU [11.7-33.7 kW]

JOB NAME _____ LOCATION _____

CONTRACTOR _____ ORDER NO. _____

ENGINEER _____ UNIT MODEL NO. _____

SUBMITTED FOR ☐ APPROVAL ☐ RECORD COIL MODEL NO. _____

DATE _____ AIR HANDLER MODEL NO. _____

UNIT DATA

HEATING PERFORMANCE

TOTAL CAPACITY INPUT* MBH [kW]

TOTAL CAPACITY OUTPUT* MBH [kW]

DESIGN TEMP. RISE..... °F [°C] DB

AFUE %

CALIFORNIA SEASONAL
EFFICIENCY %

(*uses blower motor heat)

SUPPLY AIR BLOWER PERFORMANCE

TOTAL AIR SUPPLY..... CFM [L/s]

TOTAL RESISTANCE EXTERNAL
TO UNIT..... IWG

BLOWER SPEED..... RPM

POWER OUTPUT REQUIREMENT BHP

MOTOR RATING HP [W]

POWER INPUT REQUIREMENT kW

ELECTRICAL DATA

POWER SUPPLY Hz

TOTAL UNIT AMPACITY..... AMPS

MINIMUM WIRE SIZE AWG

MAXIMUM OVERCURRENT DEVICE
FUSES/HACR BREAKER AMPS

FEATURES

- **Energy Efficiency:** ENERGY STAR® certified, featuring 95% AFUE across all model sizes
- **Diagnostics:** Industry-first, 7-Segment LED for quick and easy service
- **Ignition System:** Proven Direct Spark Ignition (DSI) for reliability and longevity
- **Water Management System:** Exclusive patented block drain sensor that automatically shuts off the furnace when the drain is blocked and alerts the contractor via diagnostic code

FIELD INSTALLED ACCESSORIES


Vent Termination Kits Concentric:

- Vertical/Horizontal 2" Pipe (US only) = RXGY-E02.....☐
- Vertical/Horizontal 2" Pipe (US & Canada) = RXGY-E02A.....☐
- Vertical/Horizontal 3" Pipe (US only) = RXGY-E03.....☐
- Vertical/Horizontal 3" Pipe (US & Canada) = RXGY-E03A.....☐

Direct Vent Furnace Side Wall Vent 2" or 3"

- (US only) = RXGY-G02☐





Dimensional Data

MODEL W951T	LEFT SIDE	MINIMUM CLEARANCE (IN.) [mm]					SHIP WGTS.	FLANGE DIMENSIONS		
		RIGHT SIDE	BACK	TOP	FRONT	VENT		A	B	C
040	0	0	0	1 [25]	2 [51]	0	123.5 [56]	171/2 [445]	1617/64 [413]	1613/64 [412]
060	0	0	0	1 [25]	2 [51]	0	128 [58]	171/2 [445]	1617/64 [413]	1613/64 [412]
070	0	0	0	1 [25]	2 [51]	0	132 [60]	171/2 [445]	1617/64 [413]	1613/64 [412]
070 (wide)	0	0	0	1 [25]	2 [51]	0	147.5 [67]	21 [533]	1949/64 [502]	1945/64 [500]
085	0	0	0	1 [25]	2 [51]	0	147.5 [67]	21 [533]	1949/64 [502]	1945/64 [500]
100	0	0	0	1 [25]	2 [51]	0	152 [69]	21 [533]	1949/64 [502]	1945/64 [500]
115	0	0	0	1 [25]	2 [51]	0	165 [75]	241/2 [662]	2317/64 [591]	2313/64 [589]

*A service clearance of at least 24" is recommended in front of all furnaces
Supply and return depicted as upflow configuration.
Flange configuration will vary depending on installation orientation.

[] Designates Metric Conversions

Before proceeding with installation, refer to installation instructions packaged with each model, as well as complying with all Federal, State, Provincial, and Local codes, regulations, and practices.